

# **APPENDIX 1**

## **Montague Elementary School**

### **LABORATORY ANALYSIS WATER SAMPLING RESULTS WITH CHAIN OF CUSTODY**

# ANALYTICAL REPORT

## PREPARED FOR

Attn: William Grennille  
Montague Elementary School  
475 Route 206 North  
Montague, New Jersey 07827

Generated 4/22/2025 5:08:01 PM

## JOB DESCRIPTION

Montague Elementary School - Lead

## JOB NUMBER

630-108220-1

# Eurofins Environment Testing Philadelphia, LLC

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Environment Testing Philadelphia, LLC Project Manager.

## Authorization



Generated  
4/22/2025 5:08:01 PM

Authorized for release by  
Erin Dougherty, Project Administrator  
[Erin.Dougherty@et.eurofinsus.com](mailto:Erin.Dougherty@et.eurofinsus.com)  
(215)355-3900

## Compliance Statement

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments. QC data that exceed the upper limits and are associated with non-detect samples are qualified but no further narration is needed since the bias is high and does not change a non-detect result. Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

### Coliform MCLs

· Based on the EPA primary drinking water standard MCL for total coliforms, a water supply is considered bacteriologically "SAFE" if no coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 cfu/100mL" or "NEG" for the coliform test. If you report indicates a positive result "POS" or a value greater than or equal to one, then your supply is "UNSAFE FOR DRINKING" contact your local health department.

### Warranties, Terms, and Conditions

· Analyses for Field Parameters are performed by Eurofins Philadelphia field staff. Locations and certifications are identified on the Chain of Custody as follows:

ERF = field staff performs tests under NJ State certification # 02015.

VL = field staff performs tests under NJ State certification # 06005.

WG = field staff performs tests under NJ State certification # PA001, PA State certification # 48-01334.

H = field staff performs tests under NJ NELAP certification # PA093, PA NELAP certification # 46-05499.

· Test results meet all TNI or other applicable regulatory agency requirements, including holding times and preservation, unless otherwise indicated.

· The report shall not be reproduced, except in full, without the written consent of the laboratory

· All samples are collected as "grab" samples unless otherwise identified.

· Reported results related only to the samples as tested. Eurofins Philadelphia is not responsible for sample integrity unless sampling has been performed by a member of our staff.

· Eurofins Philadelphia is not responsible for sampling and/or testing omissions. Note that regulatory authorities may assess substantial fines for testing omissions. Please track your sample collection schedules and results on a regular basis (e.g. weekly, monthly, or quarterly) to ensure compliance.

· Eurofins' online data portal "TotalAccess" will provide you with real-time access to collection dates and testing results. Please contact Client Services for further information.

· The following personnel or their deputies have approved the results of the tests performed by Eurofins Philadelphia : Nicki Smith (Environmental Chemistry) and Jacqueline Gartner (Water Microbiology).





## Case Narrative

Client: Montague Elementary School  
Project: Montague Elementary School - Lead

Job ID: 630-108220-1

**Job ID: 630-108220-1**

**Eurofins Environment Testing Philadelphia,**

### **Job Narrative 630-108220-1**

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

#### **Receipt**

The samples were received on 4/10/2025 2:53 PM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice.

#### **Metals**

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

## Sample Summary

Client: Montague Elementary School  
Project/Site: Montague Elementary School - Lead

Job ID: 630-108220-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
630-108220-1	RM 211 SINK	Drinking Water	04/10/25 06:45	04/10/25 14:53
630-108220-2	HALLWAY RM 209 FOUNTAIN	Drinking Water	04/10/25 06:47	04/10/25 14:53
630-108220-3	HALLWAY RM 209 BOTTLE F.	Drinking Water	04/10/25 06:49	04/10/25 14:53
630-108220-4	KITCHEN SINK LEFT	Drinking Water	04/10/25 06:51	04/10/25 14:53
630-108220-5	KITCHEN SINK RIGHT	Drinking Water	04/10/25 06:53	04/10/25 14:53
630-108220-6	HALLWAY ROOM 304 FOUNTAIN CHILLER	Drinking Water	04/10/25 06:55	04/10/25 14:53
630-108220-7	HALLWAY ROOM 304 BOTTLE F	Drinking Water	04/10/25 06:57	04/10/25 14:53
630-108220-8	HALLWAY ROOM 304 FOUNTAIN	Drinking Water	04/10/25 06:59	04/10/25 14:53
630-108220-9	HALLWAY ROOM 304 BOTTLE F	Drinking Water	04/10/25 07:01	04/10/25 14:53
630-108220-10	HALLWAY ROOM 201 FOUNTAIN	Drinking Water	04/10/25 07:03	04/10/25 14:53
630-108220-11	HALLWAY BY 201 FOUNTAIN	Drinking Water	04/10/25 07:05	04/10/25 14:53
630-108220-12	ROOM 201 TEACHERS SINK	Drinking Water	04/10/25 07:07	04/10/25 14:53
630-108220-13	ROOM 104 NURSE BATH SINK	Drinking Water	04/10/25 07:09	04/10/25 14:53
630-108220-14	RM 110 SINK	Drinking Water	04/10/25 07:11	04/10/25 14:53
630-108220-15	ROOM 114 SINK	Drinking Water	04/10/25 07:13	04/10/25 14:53
630-108220-16	ROOM 115 SINK	Drinking Water	04/10/25 07:15	04/10/25 14:53
630-108220-17	HALLWAY RM 116 FOUNTAIN CHILLER	Drinking Water	04/10/25 07:17	04/10/25 14:53
630-108220-18	HALLWAY RM 116 BOTTLE F.	Drinking Water	04/10/25 07:19	04/10/25 14:53
630-108220-19	ROOM 110 SINK	Drinking Water	04/10/25 07:21	04/10/25 14:53
630-108220-20	ROOM 117 SINK	Drinking Water	04/10/25 07:23	04/10/25 14:53

## Client Sample Results

Client: Montague Elementary School  
Project/Site: Montague Elementary School - Lead

Job ID: 630-108220-1

### Client Sample ID: RM 211 SINK

Date Collected: 04/10/25 06:45

Date Received: 04/10/25 14:53

Lab Sample ID: 630-108220-1

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 13:22	1	SAM2

### Client Sample ID: HALLWAY RM 209 FOUNTAIN

Date Collected: 04/10/25 06:47

Date Received: 04/10/25 14:53

Lab Sample ID: 630-108220-2

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 13:39	1	SAM2

### Client Sample ID: HALLWAY RM 209 BOTTLE F.

Date Collected: 04/10/25 06:49

Date Received: 04/10/25 14:53

Lab Sample ID: 630-108220-3

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 13:35	1	SAM2

### Client Sample ID: KITCHEN SINK LEFT

Date Collected: 04/10/25 06:51

Date Received: 04/10/25 14:53

Lab Sample ID: 630-108220-4

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.0011		0.0010	0.00069	mg/L		04/22/25 13:42	1	SAM2

### Client Sample ID: KITCHEN SINK RIGHT

Date Collected: 04/10/25 06:53

Date Received: 04/10/25 14:53

Lab Sample ID: 630-108220-5

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 15:51	1	SAM2

### Client Sample ID: HALLWAY ROOM 304 FOUNTAIN CHILLER

Date Collected: 04/10/25 06:55

Date Received: 04/10/25 14:53

Lab Sample ID: 630-108220-6

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 16:06	1	SAM2

### Client Sample ID: HALLWAY ROOM 304 BOTTLE F

Date Collected: 04/10/25 06:57

Date Received: 04/10/25 14:53

Lab Sample ID: 630-108220-7

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 15:54	1	SAM2

# Client Sample Results

Client: Montague Elementary School  
Project/Site: Montague Elementary School - Lead

Job ID: 630-108220-1

## Client Sample ID: HALLWAY ROOM 304 FOUNTAIN

Lab Sample ID: 630-108220-8

Date Collected: 04/10/25 06:59

Matrix: Drinking Water

Date Received: 04/10/25 14:53

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 15:57	1	SAM2

## Client Sample ID: HALLWAY ROOM 304 BOTTLE F

Lab Sample ID: 630-108220-9

Date Collected: 04/10/25 07:01

Matrix: Drinking Water

Date Received: 04/10/25 14:53

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 15:47	1	SAM2

## Client Sample ID: HALLWAY ROOM 201 FOUNTAIN

Lab Sample ID: 630-108220-10

Date Collected: 04/10/25 07:03

Matrix: Drinking Water

Date Received: 04/10/25 14:53

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.0020		0.0010	0.00069	mg/L		04/22/25 15:44	1	SAM2

## Client Sample ID: HALLWAY BY 201 FOUNTAIN

Lab Sample ID: 630-108220-11

Date Collected: 04/10/25 07:05

Matrix: Drinking Water

Date Received: 04/10/25 14:53

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.0023		0.0010	0.00069	mg/L		04/22/25 15:38	1	SAM2

## Client Sample ID: ROOM 201 TEACHERS SINK

Lab Sample ID: 630-108220-12

Date Collected: 04/10/25 07:07

Matrix: Drinking Water

Date Received: 04/10/25 14:53

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 15:41	1	SAM2

## Client Sample ID: ROOM 104 NURSE BATH SINK

Lab Sample ID: 630-108220-13

Date Collected: 04/10/25 07:09

Matrix: Drinking Water

Date Received: 04/10/25 14:53

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.0022		0.0010	0.00069	mg/L		04/22/25 15:34	1	SAM2

## Client Sample ID: RM 110 SINK

Lab Sample ID: 630-108220-14

Date Collected: 04/10/25 07:11

Matrix: Drinking Water

Date Received: 04/10/25 14:53

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.00086	J	0.0010	0.00069	mg/L		04/22/25 14:56	1	SAM2

# Client Sample Results

Client: Montague Elementary School  
Project/Site: Montague Elementary School - Lead

Job ID: 630-108220-1

## Client Sample ID: ROOM 114 SINK

Date Collected: 04/10/25 07:13

Date Received: 04/10/25 14:53

Lab Sample ID: 630-108220-15

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 15:12	1	SAM2

## Client Sample ID: ROOM 115 SINK

Date Collected: 04/10/25 07:15

Date Received: 04/10/25 14:53

Lab Sample ID: 630-108220-16

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 15:09	1	SAM2

## Client Sample ID: HALLWAY RM 116 FOUNTAIN CHILLER

Date Collected: 04/10/25 07:17

Date Received: 04/10/25 14:53

Lab Sample ID: 630-108220-17

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 15:19	1	SAM2

## Client Sample ID: HALLWAY RM 116 BOTTLE F.

Date Collected: 04/10/25 07:19

Date Received: 04/10/25 14:53

Lab Sample ID: 630-108220-18

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 15:22	1	SAM2

## Client Sample ID: ROOM 110 SINK

Date Collected: 04/10/25 07:21

Date Received: 04/10/25 14:53

Lab Sample ID: 630-108220-19

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 15:25	1	SAM2

## Client Sample ID: ROOM 117 SINK

Date Collected: 04/10/25 07:23

Date Received: 04/10/25 14:53

Lab Sample ID: 630-108220-20

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		0.0010	0.00069	mg/L		04/22/25 15:15	1	SAM2

## Action Limit Summary

Client: Montague Elementary School  
Project/Site: Montague Elementary School - Lead

Job ID: 630-108220-1

### Client Sample ID: RM 211 SINK

Lab Sample ID: 630-108220-1

#### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

### Client Sample ID: HALLWAY RM 209 FOUNTAIN

Lab Sample ID: 630-108220-2

#### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

### Client Sample ID: HALLWAY RM 209 BOTTLE F.

Lab Sample ID: 630-108220-3

#### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

### Client Sample ID: KITCHEN SINK LEFT

Lab Sample ID: 630-108220-4

#### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.0011		mg/L	0.02	0.0010	200.8	Total/NA

### Client Sample ID: KITCHEN SINK RIGHT

Lab Sample ID: 630-108220-5

#### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

### Client Sample ID: HALLWAY ROOM 304 FOUNTAIN CHILLER

Lab Sample ID: 630-108220-6

#### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

## Action Limit Summary

Client: Montague Elementary School  
Project/Site: Montague Elementary School - Lead

Job ID: 630-108220-1

**Client Sample ID: HALLWAY ROOM 304 BOTTLE F**

**Lab Sample ID: 630-108220-7**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		mg/L	0.02		0.0010	200.8	Total/NA

**Client Sample ID: HALLWAY ROOM 304 FOUNTAIN**

**Lab Sample ID: 630-108220-8**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		mg/L	0.02		0.0010	200.8	Total/NA

**Client Sample ID: HALLWAY ROOM 304 BOTTLE F**

**Lab Sample ID: 630-108220-9**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		mg/L	0.02		0.0010	200.8	Total/NA

**Client Sample ID: HALLWAY ROOM 201 FOUNTAIN**

**Lab Sample ID: 630-108220-10**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	0.0020		mg/L	0.02		0.0010	200.8	Total/NA

**Client Sample ID: HALLWAY BY 201 FOUNTAIN**

**Lab Sample ID: 630-108220-11**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	0.0023		mg/L	0.02		0.0010	200.8	Total/NA

**Client Sample ID: ROOM 201 TEACHERS SINK**

**Lab Sample ID: 630-108220-12**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		mg/L	0.02		0.0010	200.8	Total/NA

Eurofins Environment Testing Philadelphia, LLC

## Action Limit Summary

Client: Montague Elementary School  
Project/Site: Montague Elementary School - Lead

Job ID: 630-108220-1

### Client Sample ID: ROOM 104 NURSE BATH SINK

Lab Sample ID: 630-108220-13

#### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.0022		mg/L	0.02	0.0010	200.8	Total/NA

### Client Sample ID: RM 110 SINK

Lab Sample ID: 630-108220-14

#### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.00086	J	mg/L	0.02	0.0010	200.8	Total/NA

### Client Sample ID: ROOM 114 SINK

Lab Sample ID: 630-108220-15

#### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

### Client Sample ID: ROOM 115 SINK

Lab Sample ID: 630-108220-16

#### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

### Client Sample ID: HALLWAY RM 116 FOUNTAIN CHILLER

Lab Sample ID: 630-108220-17

#### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

### Client Sample ID: HALLWAY RM 116 BOTTLE F.

Lab Sample ID: 630-108220-18

#### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA



## Action Limit Summary

Client: Montague Elementary School  
Project/Site: Montague Elementary School - Lead

Job ID: 630-108220-1

**Client Sample ID: ROOM 110 SINK**

**Lab Sample ID: 630-108220-19**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

**Client Sample ID: ROOM 117 SINK**

**Lab Sample ID: 630-108220-20**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

# Accreditation/Certification and Definitions Summary

Client: Montague Elementary School  
Project/Site: Montague Elementary School - Lead

Job ID: 630-108220-1

## Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
New Jersey	NELAP	PA011	06-30-25

## Qualifiers

### Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
□	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
1C	Result is from the primary column on a dual-column method.
2C	Result is from the confirmation column on a dual-column method.
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
MRL	Method Reporting Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
SDL	Sample Detection Limit
SDL	Sample Detection Limit
SDL	Sample Detection Limit
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

## Method Summary

Client: Montague Elementary School  
Project/Site: Montague Elementary School - Lead

Job ID: 630-108220-1

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	ELLE
Non-Digest Prep	Preparation, Non-Digested Aqueous Metals	EPA	ELLE

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300







Chain of Custody Record



Environment Testing



<b>Client Information (Sub Contract Lab)</b>		Sampler: N/A	Lab Pkt: Dougherty, Erin	Carrier Tracking No(s): N/A	COC No: 630-17393.1						
Client Contact: Shipping/Receiving		Phone: N/A	E-Mail: Erin.Dougherty@et.eurofins.com	State of Origin: New Jersey	Page: Page 1 of 3						
Company: Eurofins Lancaster Laboratories Environm		Accreditations Required (See note): NELAP - New Jersey									
Address: 2425 New Holland Pike,		Due Date Requested: 4/23/2025									
City: Lancaster		TAT Requested (days): N/A									
State, Zip: PA, 17601		PO #: N/A	Sample Type (C=Comp, G=grab): N/A	Matrix (W=water, B=solid, O=soil, A=air):	Analysis Requested						
Phone: 717-656-2300(Tel)		WO #: N/A	Sample Time: 06:45 Eastern	Preservation Code: X							
Email: N/A		Project #: 63002439	Sample Date: 4/10/25	Field Filtered Sample (Yes or No): X							
Site: Montague Elementary School		SSOW#: N/A	Sample Date: 4/10/25	Perform MS/MSD (Yes or No): X							
			Sample Date: 4/10/25	200.8 SDWA/MTL ND Prep (MOD) Lead							
Sample Identification - Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, B=solid, O=soil, A=air)	Preservation Code	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	200.8 SDWA/MTL ND Prep (MOD) Lead	Total Number of Containers	Special Instructions/Note:
RM 211 SINK (630-108220-1)		4/10/25	06:45 Eastern	G	Drinking Water		X	X		1	
HALLWAY RM 209 FOUNTAIN (630-108220-2)		4/10/25	06:47 Eastern	G	Drinking Water		X	X		1	
HALLWAY RM 209 BOTTLE F. (630-108220-3)		4/10/25	06:49 Eastern	G	Drinking Water		X	X		1	
KITCHEN SINK LEFT (630-108220-4)		4/10/25	06:51 Eastern	G	Drinking Water		X	X		1	
KITCHEN SINK RIGHT (630-108220-5)		4/10/25	06:53 Eastern	G	Drinking Water		X	X		1	
HALLWAY ROOM 304 FOUNTAIN CHILLER (630-108220-6)		4/10/25	06:55 Eastern	G	Drinking Water		X	X		1	
HALLWAY ROOM 304 BOTTLE F (630-108220-7)		4/10/25	06:57 Eastern	G	Drinking Water		X	X		1	
HALLWAY ROOM 304 FOUNTAIN (630-108220-8)		4/10/25	06:59 Eastern	G	Drinking Water		X	X		1	
HALLWAY ROOM 304 BOTTLE F (630-108220-9)		4/10/25	07:01 Eastern	G	Drinking Water		X	X		1	
Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/test/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.											
<b>Possible Hazard Identification</b>											
Unconfirmed											
Deliverable Requested: I, II, III, IV, Other (specify) Primary Deliverable Rank: 1											
Empty Kit Relinquished by: _____ Date: _____ Time: _____											
Relinquished by: _____ Date/Time: 4/10/25 1453 Company: EEP											
Relinquished by: _____ Date/Time: _____ Company: _____											
Relinquished by: _____ Date/Time: _____ Company: _____											
Custody-Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No											
Custody Seal No.: Box 1											
Remarks: 15:19:30 c: 194 no fee 145/146											

## Chain of Custody Record

<b>Client Information (Sub Contract Lab)</b>				Lab PM: <b>Dougherty, Erin</b>		Carrier Tracking No(s): <b>630-17393.2</b>	
Client Contact: <b>Shipping/Receiving</b>				E-Mail: <b>Erin.Dougherty@et.eurofinsus.com</b>		Page: <b>Page 2 of 3</b>	
Company: <b>Eurofins Lancaster Laboratories Environm</b>				Accreditations Required (See note): <b>NELAP - New Jersey</b>		Job #: <b>630-108220-1</b>	
Address: <b>2425 New Holland Pike,</b>				Due Date Requested: <b>4/23/2025</b>		Preservation Codes:	
City: <b>Lancaster</b>				TAT Requested (days): <b>N/A</b>			
State, Zip: <b>PA, 17601</b>				PO #: <b>N/A</b>			
Phone: <b>717-656-2300(Tel)</b>				WO #: <b>N/A</b>			
Email: <b>N/A</b>				Project #: <b>63002439</b>			
Project Name: <b>Montague Elementary School - DW</b>				SSOW#: <b>N/A</b>			
Site: <b>Montague Elementary School</b>							

  

Sample Identification - Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=Comp, G=Grab)	Matrix (W=Water, S=Solid, O=Other)	Analysis Requested		Total Number of Containers	Special Instructions/Note:
					Field Filtered Sample (Yes or No)	200.8, SDWA/MTL, ND Prep (MOD) Lead		
HALLWAY ROOM 201 FOUNTAIN (630-108220-10)	4/10/25	07:03 Eastern	G	Drinking Water	X		1	
HALLWAY BY 201 FOUNTAIN (630-108220-11)	4/10/25	07:05 Eastern	G	Drinking Water	X		1	
ROOM 201 TEACHERS SINK (630-108220-12)	4/10/25	07:07 Eastern	G	Drinking Water	X		1	
ROOM 104 NURSE BATH SINK (630-108220-13)	4/10/25	07:09 Eastern	G	Drinking Water	X		1	
RM 110 SINK (630-108220-14)	4/10/25	07:11 Eastern	G	Drinking Water	X		1	
ROOM 114 SINK (630-108220-15)	4/10/25	07:13 Eastern	G	Drinking Water	X		1	
ROOM 115 SINK (630-108220-16)	4/10/25	07:15 Eastern	G	Drinking Water	X		1	
HALLWAY RM 116 FOUNTAIN CHILLER (630-108220-17)	4/10/25	07:17 Eastern	G	Drinking Water	X		1	
HALLWAY RM 116 BOTTLE F. (630-108220-18)	4/10/25	07:19 Eastern	G	Drinking Water	X		1	

  

Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/test/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.

  

**Possible Hazard Identification**  
 Unconfirmed  
 Deliverable Requested: I, II, III, IV, Other (specify) \_\_\_\_\_

**Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)**  
☐ Return To Client ☐ Disposal By Lab ☐ Archive For \_\_\_\_\_ Months

Special Instructions/QC Requirements:

  

Empty Kit Relinquished by:		Time:	
Date/Time	Company	Date	Company
4-10-25 1453	EEEP		

  

Primary Deliverable Rank: 1		Time:	
Date/Time	Company	Date/Time	Company
4-10-25 1453	EEEP		

  

Custody Seal No.:		Time:	
Date/Time	Company	Date/Time	Company
4-10-25 1453	EEEP		

  

Custody Seals Intact: ☒ Yes ☐ No

Other Remarks: **Box 1**



[illegible]